
DECLARATION of CONFORMITY

1. The Product Family

Premier Quatro 1-4 Loop Addressable FACP

37-500	QT/1/xx	Premier Quatro 1 loop Analogue Addr Fire Alarm Control Panel
37-501	QT/2/xx	Premier Quatro 1 loop Analogue Addr Fire Alarm Control Panel
37-502	QT/3/xx	Premier Quatro 1 loop Analogue Addr Fire Alarm Control Panel
37-503	QT/4/xx	Premier Quatro 1 loop Analogue Addr Fire Alarm Control Panel
21-503	QT-LC	Premier Quatro Loop Card
37-512	QT-NC	Premier Quatro Network Card

Where /xx represents the language of the label fitted (Blank for English)

2. These products are manufactured by Zeta Alarms Limited, at Detection House, 72-78 Morfa Road, Swansea, SA1 2EN. U.K.

3. This declaration is issued under the sole responsibility of the manufacturer.

4. The object of the declaration described in point 1 is in conformity with the relevant Union harmonisation legislation

2014/30/EU	EMC Directive
2011/65/EU	Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)
2014/35/EU	Electrical equipment designed for use within certain voltage limits (LVD)

5. References to the relevant harmonised standards used, or references to the specifications in relation to which conformity is declared:

BS EN 60950-1	Information technology Equipment – Electrical Safety – General requirements.
BS EN 61000-6-3:2007 +A1:2011	Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments. Emissions, Class B.
BS EN 50130-4:2011 +A1:2014	Alarm systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

Signed for and on behalf of Zeta Alarms Limited

Name: **N.R. P. Jones** Position: **Technical Manager**
Place of issue: **Swansea**
Date of issue: **4th February 2021**

Signature:

A handwritten signature in blue ink, appearing to be "N.R. P. Jones", written over a light blue horizontal line.