

BRE Global

Notified Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2047

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

MKII-AXTB/R Zeta Addressable Xtratone Type A Wall Sounder Beacon, Red Plastic, White Flash

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Zeta Alarms Limited
Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom

Zeta Alarms Limited
Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 – Sounders EN 54-23:2010 - Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 January 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 16 January 2018

Date of Issue: 16 January 2018

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2047**MKII-AXTB/R Zeta Addressable Xtratone Type A Wall Sounder Beacon, Red Plastic, White Flash****Notes:**

1. Meets the requirements of EN54-3 at the following tones:
 - Tone 0: 800Hz and 970Hz, 500ms each
 - Tone 8: 500Hz – 1200Hz, 3.5s sweep, 0.5s silence, repeat Dutch Slow Whoop

2. The wall mounted, Type A VAD meets the requirements of EN 54-23 for the following:
 - Coverage volume W 3.1 – 9.1
 - Flash rate 0.5Hz
 - White LED

Variants:

MKII-AXTB/W – Zeta Addressable Xtratone Type A Wall Sounder Beacon, White Plastic, White Flash



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 16 January 2018

Date of Issue: 16 January 2018

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.