

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

**2831-CPR-F4519**

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

### Smart Connect Multiloop 26 port, 1-16 Loop Analogue Addressable Control and Indicating Equipment with Printer

*(For full product details and conditions of use refer to appendix)*

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

**Zeta Alarms Limited**  
**Detection House**  
**72-78 Morfa Road**  
**Swansea**  
**SA1 2EN**  
**United Kingdom**

**Zeta Alarms Limited**  
**Detection House**  
**72-78 Morfa Road**  
**Swansea**  
**SA1 2EN**  
**United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-2:1997 + A1:2006 - Control and indicating equipment**  
**EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 16 December 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

Date of First Issue: 16 December 2021

Date of Issue: 16 December 2021

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland****Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F4519****Smart Connect Multiloop 26 port, 1-16 Loop Analogue Addressable Control and Indicating Equipment with Printer**

Incorporating the following modules:

MMP-DISP	Display PCB
MMP-TERM	Termination PCB
MMP-TERM/EXP	5 x Term Expander – 4 port
PCB/MMP-ZLX64	Zone LED Expansion PCB
PCB/PSU-UL-15	Power Supply Controller
BLD-400-V030-NNU	uPowerTek Power Supply Unit
SCM-LCM	Loop Card Module
SCM-ACM	Alarm Circuit Module
SCM-ZMM	Six Way Zone Monitor Module

Optional modules:

SCM-NM	Network Module
SCM-MIM	Six Way Multi Input Module
SCM-RM	Three Way Relay Module
SCM-PM	Printer Module

Ancillaries:


SMART/REP Smart Connect Multiloop LCD repeater

Incorporating the following modules:

MMP-DISP	Display PCB
MMP-REP_COM	Repeater communication PCB

Certified with the following options with requirements from EN 54-2: 1997:

7.8 Output to fire alarm device(s)

  
E. Mattie-Suleiman, Certification Engineer,  
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 December 2021  
Date of issue: 16 December 2021  
Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland**

**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F4519**

- 7.11 Delays to outputs
- 7.12.2 Dependencies on more than one alarm signal -Type B
- 7.12.3 Dependencies on more than one alarm signal -Type C
- 8.3 Fault signals from points
- 9.5 Disablement of each address point
- 10 Test condition

Notes:

1. Scope of approval does not include the operation of the network functionality.
2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



E. Mattie-Suleiman, Certification Engineer,  
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 December 2021

Date of issue: 16 December 2021

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)