

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00617

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): ZT-08W and ZT-08W-C Metal Cabinet Loudspeakers
(refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: Zeta Alarms Limited
72/78 Morfa Road
Swansea, SA1 2EN
United Kingdom

and produced in the manufacturing plant(s): Life Safety A/V (Guangzhou) Co., Ltd. (SG- 15578)
No. 257 (Building 3, Floors 1-2) Jun Ye Road
Guangzhou GETDD East, 510530
P. R. China

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-24:2008

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00617** on **2017-03-03** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body

0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2019-10-21

Issue: 1

Signature:



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00617

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00617

The details and conditions of use for the ZT-08W and ZT-08W-C Metal Cabinet Loudspeakers, placed on the market under the name or trade mark of:

Zeta Alarms Limited
72/78 Morfa Road
Swansea, SA1 2EN
United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-24:2008

Model	Manufacturing Location	Description
ZT-08W	SG-15578	Metal Cabinet Loudspeaker, 6/3/1.5/0.75W
ZT-08W-C		Metal Cabinet Loudspeaker, 6/3/1.5/0.75W (with Capacitor)

Conditions of use:

Suitable for indoor applications only

Approved settings:

The following line voltage, power tap and impedance settings have been approved:

Line Voltage	Impedance			
	1.7K	3.3K	6.7K	13K
100V	6 W	3 W	1.5 W	0.75 W
70V	3 W	1.5 W	0.75 W	0.375 W

General Notes:

1. Evaluated under Intertek project number 102748140 and 12057984.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.