

| DECLARATION OF PERFORMANCE According to Construction Products Regulation EU N° 305/2011 |
|--|
| DoP Ref: GLT-204-DoP-3 |
| 1. Unique Product identification code: 42-608 , 42-609 |
| 2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4): ZXTB/R , Zeta Conventional Xtratone Sounder, Red Plastic, White Flash ZXTB/W , Zeta Conventional Xtratone Sounder, White Plastic, White Flash |
| 3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer: Fire detection and fire alarm systems installed in and around buildings. (Indoor use only) |
| 4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5): Zeta Alarms Limited 72-78 Morfa Road Swansea SA1 2EN UK |
| 5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2): Not applicable |
| 6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: System 1 |
| 7. In case of the declaration of performance concerning a construction product covered by the harmonized standard: Loss Prevention Certification Board (Identification N0 0832) performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity: 0832-CPR-F1335 |
| 8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Not applicable, see item 7 |

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

| Essential characteristics | Performance | Harmonized Technical Specification | |
|---|-------------|---|--|
| | | EN54-3:2001 + A1:2002 + A2:2006 | EN54-23:2010 |
| Performance under fire conditions | Pass | 4.2 - Sound level | 4.3.1 – Coverage Volume |
| | | 4.3 - Frequency and sound pattern | 4.3.5 – light temporal pattern and flash frequency |
| | | 5.2 - Reproducibility | 5.1.7- Reproducibility |
| Operational reliability | Pass | 4.5 - Construction | 4.2.2 – Provision for external conductors |
| | | 4.6 - Marking and data | 4.3.6 – Marking and data |
| | | 5.4 - Durability | 4.2.1- Duration of operation |
| Durability of operational reliability, Temperature resistance | Pass | 5.5 - Dry heat (operational) | 4.4.1.1- Dry heat (operational) |
| | | 5.6 - Dry heat (Endurance) | 4.4.1.2- Dry heat (Endurance) |
| | | 5.7 - Cold (operational) | 4.4.1.3- Cold (operational) |
| | | 5.8 - Damp heat, cyclic (operational) | 4.4.2.1- Damp heat, cyclic (operational) |
| Durability of operational reliability, Humidity resistance | Pass | 5.8 - Damp heat, cyclic (operational) | 4.4.2.3 - Damp heat, cyclic (endurance) |
| | | 5.9 - Damp heat, steady state (endurance) | 4.4.2.2- Damp heat, steady state (endurance) |
| Durability of operational reliability, Corrosion resistance | Pass | 5.11 - Sulphur dioxide (SO ₂) corrosion (endurance) | 4.4.4 – Sulphur dioxide (SO ₂) corrosion (endurance) |
| Durability of operational reliability, Shock and Vibration resistance | Pass | 5.12 - Shock (operational) | 4.4.3.1- Shock (operational) |
| | | 5.13 - Impact (operational) | 4.4.3.2- Impact (operational) |
| | | 5.14 - Vibration, sinusoidal (operational) | 4.4.3.3- Vibration, sinusoidal (operational) |
| | | 5.15 - Vibration, sinusoidal (endurance) | 4.4.3.4- Vibration, sinusoidal (endurance) |
| Durability of operational reliability, Electrical stability | Pass | 5.16 - EMC immunity tests (operational) | 4.4.5 – Electrical stability |
| Durability of operational reliability, Resistance to Ingress | Pass | 5.17 - Enclosure protection | 4.2.4 – Enclosure protection |

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of Zeta Alarm Systems by GLT Exports Ltd by:

Name: N.R. P. Jones

Signature: 

Position: Technical Manager

Place of issue: Swansea

Date of issue: 10th January, 2018