

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

DoP Ref: GLT-199-DoP-2

1. Unique Product identification code:

80-140

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

FEAOH2000, FYREYE EXTRA ADDR OPTO-HEAT DETECTOR - 2 LED

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings. (Indoor use only)

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Zeta Alarms Limited
72-78 Morfa Road
Swansea
SA1 2EN
UK

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

DBI (Identification No 2531) performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

2531-CPR-232.1571

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

| Essential characteristics | Performance | Harmonized Technical Specification |
|---|-------------|--|
| Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions | Pass | EN54-7: 2000 A1: 2002, A2: 2006 |
| | | 4.8 - Response to slowly developing fires |
| | | 4.3 - Repeatability |
| | | 5.3 - Directional dependence |
| | | 5.4 - Reproducibility |
| | | 5.6 - Air movement |
| | | 5.7 - Dazzling |
| | | 5.18 - Fire sensitivity |
| Operational reliability | Pass | 4.2 - Individual alarm indication |
| | | 4.3 - Connection of ancillary devices |
| | | 4.4 - Monitoring of detachable detectors |
| | | 4.5 - Manufacturer's adjustments |
| | | 4.6 - On-site adjustment of response behaviour |
| | | 4.7 - Protection against the ingress of foreign bodies |
| | | 4.9 - Marking |
| | | 4.10 - Data |
| | | 4.11 - Additional requirements for software controlled detectors |
| | | 5.5 - Variation in supply parameters |
| Tolerance to supply voltage | Pass | 4.11 - Additional requirements for software controlled detectors |
| | | 5.7 - Variation in supply parameters |
| Durability of operational reliability and response delay, Temperature resistance | Pass | 5.8 - Dry heat (operational) |
| | | 5.9 - Cold (operational) |
| Durability of operational reliability, Vibration resistance | Pass | 5.13 - Shock (operational) |
| | | 5.14 - Impact (operational) |
| | | 5.15 - Vibration, sinusoidal (operational) |
| Durability of operational reliability, Humidity resistance | Pass | 5.16 - Vibration, sinusoidal (endurance) |
| | | 5.10 - Damp heat, steady state (operational) |
| Durability of operational reliability, Corrosion resistance | Pass | 5.11 - Damp heat, steady state (endurance) |
| | | 5.12 - Sulphur dioxide (SO2) corrosion (endurance) |
| Durability of operational reliability, Electrical stability | Pass | 5.17 - Electromagnetic compatibility (EMC), immunity tests (operational) |
| | | 5.18 - Electromagnetic compatibility (EMC), immunity tests (operational) |

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of **Zeta Alarms Limited** by:

Name: **N.R. P. Jones**

Signature:



Position: **Technical Manager**

Place of issue: **Swansea**

Date of issue: **20th February 2017**