

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

DoP Ref: GLT- 136-DoP-1

1. Unique Product identification code:

46-300 , 46-305

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

PP-2/12 Premier Power Pack EN54-4 2.0A PSE with LCD

PP-5/17 Premier Power Pack EN54-4 5.0A PSE with LCD

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings. (Indoor use only)

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Zeta Alarms Limited

72-78 Morfa Road

Swansea

SA1 2EN

UK

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

Intertek Life Safety and Security (Identification NO 0359) performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

0359-CPR-00146

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Performance	Harmonized Technical Specification
		EN 54-4: 1997 + A2: 2006
Operational reliability	Pass	4 - General requirements
		5 - Functions
		6 - Materials, design and manufacture
		7 - Documentation
		8 - Marking
Durability of operational reliability Temperature resistance	Pass	9.5 - Cold (operational)
Durability of operational reliability Vibration resistance	Pass	9.7 - Impact (operational)
		9.8 - Vibration, sinusoidal (operational)
		9.15 - Vibration, sinusoidal (operational)
Durability of operational reliability Electrical stability	Pass	9.9 - Electromagnetic Compatibility (EMC), Immunity tests (operational)
Durability of operational reliability Humidity resistance	Pass	9.6 - Damp heat, steady state (operational)
		9.14 - Damp heat, steady state (endurance)
Performance of power supply	Pass	4 - General requirements
		5 - Functions
		6 - Materials, design and manufacture

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of Zeta Alarm Systems by GLT Exports Ltd by:

Name: N.R. P. Jones

Signature:



Position: Technical Manager

Place of issue: Swansea

Date of issue: 10th January 2018