

Certificate of Product Approval

Certificate Number: 330p

Issue: 04

Zeta Alarms Limited

Detection House
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Multi-Sensor / Multi-Criteria Detectors

MKII-OH

MKII-AOH

(refer to Appendix for details)

Standards

EN 54-5:2000 + A1:2002

EN 54-7:2000 + A1:2002 + A2:2006

CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

14 June 2017

Date of Issue

10 May 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 330p

Issue: 04

Zeta Alarms Limited

Certified Product	Description	LPCB Ref.No.
MKII-OH	Fyreye II Conventional Optical and Heat Detector (MKII-CB/D Base and MKII-CB Base) Notes: 1. Meets the requirements of EN 54-7:2000 at Smoke Sensitivity setting Range: 0.08%dB ~ 0.12%dB. 2. Meets the requirements of EN 54-5:2000 at Class A2	330p/01
MKII-AOH	Fyreye II Addressable Optical and Heat Detector (MKII-CB/D Base and MKII-CB Base) Notes: 1. Meets the requirements of EN 54-7:2000 at Smoke Sensitivity setting Range: 0.09%dB ~ 0.12%dB. 2. Meets the requirements of EN 54-5:2000 at Class A1	330p/02

Bases

MKII-CB	Shallow Base
MKII-CB/D	Deep Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

14 June 2017
Date of Issue

10 May 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.

