



## Annex 1

### EXTENT

#### Type:

Fyreye detector type FEAOH2000 MULTI DETECTOR  
Analogue addressable Smoke and Heat detector with output for LED  
Must be installed in Fyreye Common Base Part no. 45681-200GLT.

#### Performance

Essential characteristics	Clauses in EN 54-5:2000	Performance
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1 <sup>a</sup> , 6.2 <sup>b</sup>	Pass
Operational reliability	4.4 to 4.11	Pass
Tolerance to supply voltage	5.7	Pass
Durability of operational reliability and response delay; temperature resistance	5.9, 5.10	Pass
Durability of operational reliability; vibration resistance	5.14, 5.17	Pass
Durability of operational reliability; humidity resistance	5.11, 5.12	Pass
Durability of operational reliability; corrosion resistance	5.13	Pass
Durability of operational reliability; electrical stability	5.18	Pass

Essential characteristics	Clauses in EN 54-7:2000	Performance
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	Pass
Operational reliability	4.2 to 4.7, 4.9 to 4.11	Pass
Tolerance to supply voltage	5.5	Pass
Durability of operational reliability and response delay; temperature resistance	5.8, 5.9	Pass
Durability of operational reliability; vibration resistance	5.13, 5.16	Pass
Durability of operational reliability; humidity resistance	5.10, 5.11	Pass
Durability of operational reliability; corrosion resistance	5.12	Pass
Durability of operational reliability; electrical stability	5.17	Pass

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

# Certificate No.: 2531-CPR-232.1571

Issue date: 2017-09-29



Annex 2

## TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
DELTA	DANAK-199813, Rev. 1	2007-01-11
DELTA	DANAK-199748	2005-04-21

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

### DBI Certification A/S

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)



Version 2015-10-23  
Page 3 of 4

Annex 3

## TECHNICAL BASIS

File Number	Title	Date
WizMart  GLT-FEA2000 document  - For DBI Certificate Application	RD06-GLT00, Version 1.1	2006-11-14

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

### DBI Certification A/S

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)



DANAK  
Prod. Reg. Nr. 7023

Version 2015-10-23  
Page 4 of 4